



Indoor Luminaire Photometric Data

Description Information

Luminary Name: 55252		Lum. Catalog:	Test ID:
Lamp Name:		Lamp Catalog:	Test Date: 2024/06/28
Manufacture:		Shld. Ang(°):	Test Machine:GON-2000
Test Lab:		Frequency (Hz):	Lamp CCT (K): Ra:
Lum. Size(W*L*H):0.050m*-0.050m*0.000m		Lum. Area (m2):0.002	Lum. W (kg): 0.000
Test System: C, γ	Test Step: C=30.0 γ=1.0	Temp. (°C): 25	Humidity(%): 50.0


Character Parameter

Lamp Speciality Parameter		Luminaire Speciality Parameter	
Rated Flux(lm): 1421.910	Luminary Flux(lm): 1421.908	Field Angle(10%Imax): 98.0(°)	
Rated Power(W):	Luminary Efficiency: 100.00%	Down Lumens&Percent: 1418.809lm 99.78%	
Rated Voltage(V):	Luminary EER(lm/W): 61.930	Up Lumens&Percent: 3.099lm 0.22%	
Tested Power(W): 22.960	Max. Candela(cd): 2098.201	S/MH: C0_a180=1.022 C90_270=1.334	
Lamps' Inside: 1	Max Cand@Ang. (°): C=300.0 γ=22.0	CIE Type: Semi-Direct	
Tested Electrics(V, A, pf):229.8, 0.104, 0.957	Beam Angle(50%Imax): 35.3(°)	ErP Φ use(90°): 862.491lm	
Lamp Size(W*L*H):0.050m*-0.050m*0.000m	Left=9.4°, Right=44.8°	IRF(%): 226.850	



2D Plane Light Intensity Distribution Curve


Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date:2024/06/28



3D Light Intensity Distribution Modal

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28

3D Light Intensity Distribution Modal



Curves:

View Angles:

3D Model

Orient:0

Fixture

Tilt:0

Vert. HUD

Roll:0

Hori. HUD

Spin:0

IES Indoor Report

Photometric Filename:UL-25W-COB-2500-LH.IES

Zonal Flux Tabulation

Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
0.0-1.0	0.41	0.41	0.03	0.03	47.0-48.0	22.14	1025.02	1.56	72.09
1.0-2.0	1.20	1.61	0.08	0.11	48.0-49.0	21.53	1046.55	1.51	73.60
2.0-3.0	2.03	3.64	0.14	0.26	49.0-50.0	20.91	1067.46	1.47	75.07
3.0-4.0	2.91	6.55	0.20	0.46	50.0-51.0	20.29	1087.75	1.43	76.50
4.0-5.0	3.84	10.39	0.27	0.73	51.0-52.0	19.67	1107.43	1.38	77.88
5.0-6.0	4.85	15.25	0.34	1.07	52.0-53.0	19.05	1126.48	1.34	79.22
6.0-7.0	5.95	21.19	0.42	1.49	53.0-54.0	18.44	1144.92	1.30	80.52
7.0-8.0	7.14	28.33	0.50	1.99	54.0-55.0	17.83	1162.74	1.25	81.77
8.0-9.0	8.43	36.77	0.59	2.59	55.0-56.0	17.21	1179.95	1.21	82.98
9.0-10.0	9.82	46.59	0.69	3.28	56.0-57.0	16.59	1196.54	1.17	84.15
10.0-11.0	11.31	57.90	0.80	4.07	57.0-58.0	15.97	1212.51	1.12	85.27
11.0-12.0	12.90	70.80	0.91	4.98	58.0-59.0	15.36	1227.88	1.08	86.35
12.0-13.0	14.58	85.38	1.03	6.00	59.0-60.0	14.76	1242.64	1.04	87.39
13.0-14.0	16.30	101.68	1.15	7.15	60.0-61.0	14.17	1256.81	1.00	88.39
14.0-15.0	18.03	119.71	1.27	8.42	61.0-62.0	13.59	1270.40	0.96	89.34
15.0-16.0	19.76	139.47	1.39	9.81	62.0-63.0	12.99	1283.39	0.91	90.26
16.0-17.0	21.43	160.90	1.51	11.32	63.0-64.0	12.38	1295.77	0.87	91.13
17.0-18.0	23.04	183.94	1.62	12.94	64.0-65.0	11.76	1307.53	0.83	91.96
18.0-19.0	24.56	208.50	1.73	14.66	65.0-66.0	11.14	1318.67	0.78	92.74
19.0-20.0	25.97	234.47	1.83	16.49	66.0-67.0	10.52	1329.19	0.74	93.48
20.0-21.0	27.26	261.73	1.92	18.41	67.0-68.0	9.90	1339.09	0.70	94.18
21.0-22.0	28.39	290.12	2.00	20.40	68.0-69.0	9.28	1348.37	0.65	94.83
22.0-23.0	29.33	319.45	2.06	22.47	69.0-70.0	8.67	1357.04	0.61	95.44
23.0-24.0	30.14	349.58	2.12	24.59	70.0-71.0	8.06	1365.09	0.57	96.00
24.0-25.0	30.79	380.37	2.17	26.75	71.0-72.0	7.45	1372.55	0.52	96.53
25.0-26.0	31.24	411.62	2.20	28.95	72.0-73.0	6.85	1379.40	0.48	97.01
26.0-27.0	31.53	443.15	2.22	31.17	73.0-74.0	6.25	1385.65	0.44	97.45
27.0-28.0	31.67	474.81	2.23	33.39	74.0-75.0	5.66	1391.31	0.40	97.85
28.0-29.0	31.65	506.47	2.23	35.62	75.0-76.0	5.06	1396.37	0.36	98.20
29.0-30.0	31.53	538.00	2.22	37.84	76.0-77.0	4.48	1400.85	0.31	98.52
30.0-31.0	31.32	569.31	2.20	40.04	77.0-78.0	3.90	1404.75	0.27	98.79
31.0-32.0	30.99	600.30	2.18	42.22	78.0-79.0	3.34	1408.08	0.23	99.03
32.0-33.0	30.58	630.88	2.15	44.37	79.0-80.0	2.80	1410.88	0.20	99.22
33.0-34.0	30.13	661.01	2.12	46.49	80.0-81.0	2.29	1413.17	0.16	99.39
34.0-35.0	29.65	690.66	2.09	48.57	81.0-82.0	1.81	1414.98	0.13	99.51
35.0-36.0	29.15	719.81	2.05	50.62	82.0-83.0	1.38	1416.36	0.10	99.61
36.0-37.0	28.62	748.43	2.01	52.64	83.0-84.0	1.00	1417.36	0.07	99.68
37.0-38.0	28.07	776.50	1.97	54.61	84.0-85.0	0.68	1418.04	0.05	99.73
38.0-39.0	27.51	804.01	1.93	56.54	85.0-86.0	0.43	1418.47	0.03	99.76
39.0-40.0	26.94	830.95	1.89	58.44	86.0-87.0	0.23	1418.70	0.02	99.77
40.0-41.0	26.35	857.31	1.85	60.29	87.0-88.0	0.09	1418.79	0.01	99.78
41.0-42.0	25.77	883.08	1.81	62.10	88.0-89.0	0.02	1418.81	0.00	99.78
42.0-43.0	25.18	908.25	1.77	63.88	89.0-90.0	0.00	1418.81	0.00	99.78
43.0-44.0	24.58	932.83	1.73	65.60	90.0-91.0	0.00	1418.81	0.00	99.78
44.0-45.0	23.97	956.80	1.69	67.29	91.0-92.0	0.00	1418.81	0.00	99.78
45.0-46.0	23.35	980.15	1.64	68.93	92.0-93.0	0.00	1418.81	0.00	99.78
46.0-47.0	22.74	1002.88	1.60	70.53	93.0-94.0	0.00	1418.81	0.00	99.78

IES Indoor Report


Photometric Filename:UL-25W-COB-2500-LH.IES

Zonal Flux Tabulation - (Cont.)

Zone( γ )	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone( γ )	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94.0-95.0	0.00	1418.81	0.00	99.78	141.0-142.0	0.08	1420.62	0.01	99.91
95.0-96.0	0.00	1418.81	0.00	99.78	142.0-143.0	0.08	1420.70	0.01	99.91
96.0-97.0	0.00	1418.81	0.00	99.78	143.0-144.0	0.07	1420.77	0.01	99.92
97.0-98.0	0.00	1418.81	0.00	99.78	144.0-145.0	0.07	1420.84	0.01	99.93
98.0-99.0	0.00	1418.81	0.00	99.78	145.0-146.0	0.07	1420.91	0.00	99.93
99.0-100.0	0.00	1418.81	0.00	99.78	146.0-147.0	0.07	1420.98	0.00	99.93
100.0-101.0	0.00	1418.81	0.00	99.78	147.0-148.0	0.07	1421.05	0.00	99.94
101.0-102.0	0.00	1418.81	0.00	99.78	148.0-149.0	0.06	1421.11	0.00	99.94
102.0-103.0	0.00	1418.81	0.00	99.78	149.0-150.0	0.06	1421.17	0.00	99.95
103.0-104.0	0.00	1418.81	0.00	99.78	150.0-151.0	0.06	1421.23	0.00	99.95
104.0-105.0	0.00	1418.81	0.00	99.78	151.0-152.0	0.06	1421.28	0.00	99.96
105.0-106.0	0.00	1418.81	0.00	99.78	152.0-153.0	0.05	1421.34	0.00	99.96
106.0-107.0	0.00	1418.81	0.00	99.78	153.0-154.0	0.05	1421.39	0.00	99.96
107.0-108.0	0.00	1418.81	0.00	99.78	154.0-155.0	0.05	1421.43	0.00	99.97
108.0-109.0	0.00	1418.81	0.00	99.78	155.0-156.0	0.04	1421.48	0.00	99.97
109.0-110.0	0.00	1418.81	0.00	99.78	156.0-157.0	0.04	1421.52	0.00	99.97
110.0-111.0	0.01	1418.82	0.00	99.78	157.0-158.0	0.04	1421.56	0.00	99.98
111.0-112.0	0.01	1418.83	0.00	99.78	158.0-159.0	0.04	1421.59	0.00	99.98
112.0-113.0	0.02	1418.85	0.00	99.78	159.0-160.0	0.03	1421.62	0.00	99.98
113.0-114.0	0.02	1418.87	0.00	99.79	160.0-161.0	0.03	1421.66	0.00	99.98
114.0-115.0	0.02	1418.89	0.00	99.79	161.0-162.0	0.03	1421.69	0.00	99.98
115.0-116.0	0.03	1418.92	0.00	99.79	162.0-163.0	0.03	1421.71	0.00	99.99
116.0-117.0	0.03	1418.95	0.00	99.79	163.0-164.0	0.02	1421.74	0.00	99.99
117.0-118.0	0.04	1418.99	0.00	99.79	164.0-165.0	0.02	1421.76	0.00	99.99
118.0-119.0	0.04	1419.03	0.00	99.80	165.0-166.0	0.02	1421.78	0.00	99.99
119.0-120.0	0.04	1419.07	0.00	99.80	166.0-167.0	0.02	1421.80	0.00	99.99
120.0-121.0	0.05	1419.12	0.00	99.80	167.0-168.0	0.02	1421.82	0.00	99.99
121.0-122.0	0.05	1419.17	0.00	99.81	168.0-169.0	0.02	1421.83	0.00	99.99
122.0-123.0	0.05	1419.22	0.00	99.81	169.0-170.0	0.01	1421.84	0.00	100.00
123.0-124.0	0.06	1419.28	0.00	99.82	170.0-171.0	0.01	1421.86	0.00	100.00
124.0-125.0	0.06	1419.34	0.00	99.82	171.0-172.0	0.01	1421.87	0.00	100.00
125.0-126.0	0.06	1419.40	0.00	99.82	172.0-173.0	0.01	1421.88	0.00	100.00
126.0-127.0	0.07	1419.47	0.00	99.83	173.0-174.0	0.01	1421.89	0.00	100.00
127.0-128.0	0.07	1419.54	0.00	99.83	174.0-175.0	0.01	1421.89	0.00	100.00
128.0-129.0	0.07	1419.61	0.00	99.84	175.0-176.0	0.01	1421.90	0.00	100.00
129.0-130.0	0.07	1419.68	0.01	99.84	176.0-177.0	0.00	1421.90	0.00	100.00
130.0-131.0	0.07	1419.75	0.01	99.85	177.0-178.0	0.00	1421.91	0.00	100.00
131.0-132.0	0.08	1419.83	0.01	99.85	178.0-179.0	0.00	1421.91	0.00	100.00
132.0-133.0	0.08	1419.90	0.01	99.86	179.0-180.0	0.00	1421.91	0.00	100.00
133.0-134.0	0.08	1419.98	0.01	99.86					
134.0-135.0	0.08	1420.06	0.01	99.87					
135.0-136.0	0.08	1420.14	0.01	99.88					
136.0-137.0	0.08	1420.22	0.01	99.88					
137.0-138.0	0.08	1420.31	0.01	99.89					
138.0-139.0	0.08	1420.39	0.01	99.89					
139.0-140.0	0.08	1420.47	0.01	99.90					
140.0-141.0	0.08	1420.55	0.01	99.90					

Rectangle ISO Lighting Intensity Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28




**Photometric Filename:UL-25W-COB-2500-LH.IES**

## Plane ISO-Illuminance Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28

### Plane ISO-Illuminance Curve



Working Plane Luminaire Mounting Height(m): 3.00


Working Plane Maximum Illuminance(lx): 190.02

Working Plane Maximum Illuminance Position(d/h):H-0.3 V0.2

3D Plane ISO Illuminance Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28

3D Plane Illuminance Modal






Space ISO Illuminance Diagram

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28


Space ISO Illuminance Curve



Space Plane Maximum Illuminance and @Angle:983.85lx,14.0deg  
Plane Maximum Lighting Intensity and @Angle:1092.686cd,0eg

Illuminance-Distance Diagram

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28



Indoor Luminance Limiting Curves

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28


Glare Grade Table

GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table

Gama (deg)	45	50	55	60	65	70	75	80	85
C0	212728	169446	131024	98492	71137	44465	17163	0	0
C90	3248	1981	1311	544	386	0	0	0	0

Luminance Limiting Curve



Luminous Size:

Length(m)=-0.050

Width(m)=-0.050

Height(m)=0.000

Area(m^2)=0.001963

Luminous Type:

Without Luminous Side


Luminous Curves:

C0-C180 Color:

C90-C270 Color:

Indoor Budgetary Estimate Table

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28



Indoor Coefficient of Utilization Table

Lum. Name:55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28

Coefficients of Utilization – Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	110	106	103	100	108	104	101	98	100	97	95	96	94	92	92	91	89	87
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75
3	94	85	77	72	92	83	76	71	80	74	70	77	73	69	75	71	67	65
4	87	76	68	62	85	75	67	62	72	66	61	70	65	60	68	63	59	57
5	80	69	61	55	78	68	60	54	66	59	54	64	58	53	62	57	53	51
6	75	62	54	48	73	62	54	48	60	53	48	58	52	47	57	51	47	45
7	70	57	49	43	68	56	49	43	55	48	43	53	47	43	52	47	42	40
8	65	52	45	39	63	52	44	39	50	44	39	49	43	38	48	42	38	36
9	61	48	41	35	60	48	40	35	47	40	35	46	39	35	45	39	35	33
10	57	45	37	32	56	44	37	32	43	37	32	42	36	32	42	36	32	30

Unified Glare Rating Table

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/06/28

Unified Glare Rating Table

Ceiling RCC		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size		Vewed crosswise					Vewed endwise				
X=2H	Y=2H	34.0	35.6	34.4	35.9	36.2	6.0	7.5	6.3	7.8	8.2
	Y=3H	34.5	35.9	34.9	36.2	36.6	5.8	7.2	6.2	7.6	7.9
	Y=4H	34.6	35.9	35.0	36.3	36.6	5.7	7.1	6.1	7.4	7.8
	Y=6H	34.5	35.8	35.0	36.2	36.6	5.7	6.9	6.1	7.3	7.7
	Y=8H	34.5	35.7	34.9	36.1	36.5	5.6	6.8	6.1	7.2	7.6
	Y=12H	34.5	35.6	34.9	36.0	36.4	5.6	6.7	6.0	7.1	7.6
X=4H	Y=2H	35.1	36.4	35.5	36.8	37.1	6.6	7.9	7.0	8.3	8.7
	Y=3H	36.0	37.2	36.4	37.6	38.0	6.5	7.6	6.9	8.0	8.4
	Y=4H	36.3	37.3	36.7	37.7	38.2	6.4	7.4	6.8	7.8	8.3
	Y=6H	36.3	37.3	36.8	37.7	38.2	6.3	7.2	6.7	7.7	8.1
	Y=8H	36.3	37.2	36.8	37.6	38.1	6.2	7.1	6.7	7.6	8.0
	Y=12H	36.3	37.1	36.8	37.6	38.0	6.2	7.0	6.7	7.5	8.0
X=8H	Y=4H	36.7	37.6	37.1	38.0	38.5	6.4	7.3	6.9	7.7	8.2
	Y=6H	36.9	37.6	37.4	38.1	38.7	6.3	7.1	6.8	7.6	8.2
	Y=8H	36.9	37.6	37.4	38.1	38.6	6.2	6.9	6.7	7.5	7.9
	Y=12H	36.9	37.5	37.4	38.0	38.6	6.2	6.8	6.7	7.3	7.9
X=12H	Y=4H	36.7	37.5	37.2	38.0	38.5	6.4	7.2	6.8	7.6	8.1
	Y=6H	36.9	37.6	37.4	38.1	38.6	6.3	7.0	6.8	7.4	8.0
	Y=8H	37.0	37.6	37.5	38.1	38.7	6.2	6.8	6.7	7.3	7.9
Variations with the objverver position at spacings											
S=1.0H		0.8/-1.0					0.0/0.0				
S=1.5H		1.6/-2.1					0.0/0.0				
S=2.0H		2.8/-2.6					8.4/0.0				
Reduced UGR Table:											
Nordic Standard Table:		BK0					BK0				
Correction Value		1.9					0.5				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

IES Indoor Report

Photometric Filename:UL-25W-COB-2500-LH.IES

---

Candela Tabulation

V/H	C0. 0	C30. 0	C60. 0	C90. 0	C120. 0	C150. 0	C180. 0	C210. 0	C240. 0	C270. 0	C300. 0	C330. 0
γ 0. 0	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70	440. 70
γ 1. 0	624. 92	432. 96	345. 35	339. 10	340. 50	341. 08	562. 30	467. 66	402. 08	383. 93	373. 12	380. 24
γ 2. 0	657. 99	415. 28	318. 57	323. 09	334. 91	327. 10	535. 36	475. 54	429. 59	414. 13	398. 92	412. 31
γ 3. 0	692. 77	394. 81	291. 02	309. 42	334. 52	319. 50	506. 11	483. 12	458. 77	457. 34	441. 82	455. 28
γ 4. 0	731. 73	377. 78	267. 91	300. 30	332. 99	312. 91	474. 40	477. 24	488. 70	508. 03	498. 83	505. 77
γ 5. 0	772. 72	362. 01	246. 50	294. 46	331. 89	308. 30	444. 69	472. 31	514. 55	565. 45	565. 98	566. 89
γ 6. 0	814. 37	347. 03	225. 65	287. 01	327. 25	302. 65	412. 01	454. 08	535. 95	634. 79	656. 19	640. 08
γ 7. 0	855. 80	332. 23	209. 34	277. 79	318. 78	292. 30	383. 96	436. 15	557. 13	711. 67	762. 53	724. 69
γ 8. 0	895. 37	320. 46	197. 21	265. 96	312. 34	281. 03	357. 78	412. 28	579. 09	796. 81	876. 97	816. 34
γ 9. 0	934. 35	309. 47	186. 15	252. 51	303. 54	269. 82	332. 28	389. 95	601. 90	887. 05	995. 79	909. 86
γ 10. 0	972. 29	297. 48	177. 86	239. 43	297. 97	257. 72	309. 76	368. 11	624. 79	974. 28	1120. 73	1010. 49
γ 11. 0	1006. 49	285. 92	169. 26	224. 50	294. 73	247. 77	287. 50	343. 76	648. 19	1061. 48	1253. 30	1111. 61
γ 12. 0	1035. 07	273. 96	161. 71	213. 97	290. 66	238. 58	266. 60	324. 46	671. 43	1150. 79	1383. 39	1220. 84
γ 13. 0	1058. 67	261. 64	154. 61	204. 11	288. 02	230. 58	248. 85	303. 57	695. 27	1235. 69	1506. 50	1323. 34
γ 14. 0	1077. 00	250. 21	146. 89	195. 59	283. 88	223. 56	232. 86	285. 34	718. 39	1314. 36	1618. 20	1421. 72
γ 15. 0	1089. 11	238. 40	138. 49	187. 64	279. 32	216. 86	221. 16	269. 29	734. 86	1385. 98	1714. 43	1516. 67
γ 16. 0	1092. 69	227. 13	130. 06	180. 35	274. 05	208. 28	210. 19	254. 33	751. 87	1446. 59	1808. 59	1602. 46
γ 17. 0	1090. 93	215. 30	120. 49	172. 22	268. 35	200. 01	199. 55	237. 98	762. 14	1493. 69	1891. 62	1677. 21
γ 18. 0	1081. 69	203. 46	111. 64	163. 52	262. 44	191. 43	191. 31	222. 82	769. 70	1533. 49	1962. 46	1743. 41
γ 19. 0	1066. 21	191. 99	103. 25	155. 75	256. 46	184. 23	181. 56	209. 15	770. 07	1565. 55	2019. 97	1797. 96
γ 20. 0	1045. 11	180. 93	95. 72	148. 03	251. 13	176. 67	171. 25	196. 46	765. 17	1590. 72	2061. 07	1842. 55
γ 21. 0	1020. 95	170. 28	87. 86	141. 52	243. 67	170. 62	160. 63	184. 30	757. 69	1607. 67	2094. 97	1873. 25
γ 22. 0	990. 27	159. 18	80. 91	135. 58	233. 31	164. 12	149. 45	172. 36	744. 53	1617. 63	2098. 20	1894. 04
γ 23. 0	960. 45	148. 38	76. 27	129. 07	222. 34	157. 22	139. 37	160. 35	726. 58	1619. 43	2089. 88	1902. 61
γ 24. 0	925. 82	137. 84	71. 32	123. 39	209. 40	149. 04	130. 21	148. 96	707. 33	1613. 19	2089. 03	1902. 56
γ 25. 0	890. 22	127. 29	66. 82	116. 28	192. 78	139. 97	121. 31	139. 39	684. 22	1601. 72	2071. 82	1890. 00
γ 26. 0	854. 16	116. 75	62. 98	108. 42	173. 20	131. 36	113. 03	130. 94	659. 02	1583. 83	2034. 63	1873. 62
γ 27. 0	817. 46	107. 19	59. 22	100. 49	152. 07	121. 64	105. 53	121. 17	631. 32	1560. 26	1994. 18	1853. 77
γ 28. 0	779. 97	98. 31	55. 39	91. 97	130. 36	111. 18	98. 80	113. 22	604. 82	1535. 94	1942. 26	1821. 91
γ 29. 0	742. 96	89. 74	51. 56	83. 85	107. 39	99. 99	92. 75	104. 92	576. 68	1507. 52	1890. 69	1784. 86
γ 30. 0	705. 04	82. 02	48. 05	75. 20	86. 25	88. 70	87. 21	98. 00	549. 15	1476. 25	1838. 71	1746. 32
γ 31. 0	668. 30	75. 23	44. 66	66. 13	67. 11	77. 90	81. 63	90. 99	523. 20	1439. 46	1781. 68	1707. 26
γ 32. 0	630. 81	68. 75	41. 32	58. 31	46. 75	66. 27	76. 23	84. 42	497. 07	1399. 41	1723. 96	1663. 99
γ 33. 0	596. 69	63. 17	38. 19	50. 51	29. 07	54. 95	70. 74	78. 51	473. 05	1360. 26	1665. 44	1617. 36
γ 34. 0	563. 90	58. 12	35. 29	42. 50	18. 73	44. 31	65. 52	72. 87	449. 70	1321. 28	1607. 21	1569. 14
γ 35. 0	532. 85	53. 62	32. 66	35. 67	11. 99	34. 85	60. 53	67. 53	425. 99	1281. 48	1549. 98	1520. 86
γ 36. 0	503. 36	49. 46	30. 19	29. 35	10. 38	26. 74	55. 97	62. 60	402. 63	1242. 14	1492. 89	1470. 78
γ 37. 0	475. 52	45. 75	27. 97	24. 27	9. 10	20. 25	51. 63	58. 67	383. 40	1201. 03	1436. 56	1420. 41
γ 38. 0	448. 64	42. 11	25. 82	19. 88	8. 04	14. 85	47. 74	54. 44	364. 52	1159. 45	1381. 23	1371. 81
γ 39. 0	423. 76	39. 02	24. 07	15. 89	7. 08	11. 10	43. 97	51. 02	346. 88	1121. 03	1326. 50	1323. 53
γ 40. 0	399. 01	35. 99	22. 37	12. 58	6. 46	8. 25	40. 49	47. 70	330. 10	1082. 32	1274. 22	1275. 50
γ 41. 0	376. 20	33. 30	20. 84	9. 77	5. 85	6. 55	37. 27	44. 52	314. 49	1044. 27	1223. 71	1229. 56
γ 42. 0	354. 46	30. 65	19. 42	7. 71	5. 26	5. 75	34. 45	41. 43	298. 96	1006. 61	1175. 57	1184. 70
γ 43. 0	333. 44	28. 32	18. 08	6. 24	4. 23	5. 07	31. 95	38. 81	284. 46	970. 96	1128. 69	1141. 05
γ 44. 0	314. 46	26. 06	17. 00	5. 10	3. 14	4. 52	29. 63	36. 08	269. 88	936. 38	1083. 22	1097. 31
γ 45. 0	295. 35	23. 98	15. 93	4. 51	2. 47	4. 11	27. 42	33. 75	256. 28	902. 77	1038. 46	1055. 27
γ 46. 0	277. 94	22. 08	14. 92	3. 90	2. 11	3. 72	25. 44	31. 52	243. 34	868. 59	995. 62	1014. 77

# IES Indoor Report

## Candela Tabulation - (Cont.)

[illegible]



IES Indoor Report

Photometric Filename:UL-25W-COB-2500-LH.IES

---

Candela Tabulation - (Cont.)

V/H	C0. 0	C30. 0	C60. 0	C90. 0	C120. 0	C150. 0	C180. 0	C210. 0	C240. 0	C270. 0	C300. 0	C330. 0
γ 94. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 95. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 96. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 97. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 98. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 99. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 100. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 101. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 102. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 103. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 104. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 105. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 106. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 107. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 108. 0	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 109. 0	0. 00	0. 00	0. 00	0. 00	0. 13	0. 20	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 110. 0	0. 00	0. 00	0. 00	0. 00	0. 32	0. 40	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 111. 0	0. 00	0. 00	0. 00	0. 00	0. 50	0. 62	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 112. 0	0. 00	0. 00	0. 00	0. 00	0. 73	0. 89	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 113. 0	0. 00	0. 00	0. 00	0. 00	0. 97	1. 18	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 114. 0	0. 00	0. 00	0. 00	0. 00	1. 21	1. 40	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 115. 0	0. 00	0. 00	0. 00	0. 00	1. 48	1. 69	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 116. 0	0. 00	0. 00	0. 00	0. 00	1. 74	1. 94	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 117. 0	0. 00	0. 00	0. 00	0. 00	1. 97	2. 24	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 118. 0	0. 00	0. 00	0. 00	0. 00	2. 17	2. 50	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 119. 0	0. 00	0. 00	0. 00	0. 00	2. 35	2. 85	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 120. 0	0. 00	0. 00	0. 00	0. 00	2. 60	3. 11	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 121. 0	0. 00	0. 00	0. 00	0. 00	2. 83	3. 35	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 122. 0	0. 00	0. 00	0. 00	0. 00	3. 01	3. 72	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 123. 0	0. 00	0. 00	0. 00	0. 00	3. 26	3. 99	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 124. 0	0. 00	0. 00	0. 00	0. 00	3. 38	4. 26	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 125. 0	0. 00	0. 00	0. 00	0. 00	3. 63	4. 57	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 126. 0	0. 00	0. 00	0. 00	0. 00	3. 75	4. 88	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 127. 0	0. 00	0. 00	0. 00	0. 00	3. 93	5. 17	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 128. 0	0. 00	0. 00	0. 00	0. 00	4. 14	5. 43	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 129. 0	0. 00	0. 00	0. 00	0. 00	4. 31	5. 77	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 130. 0	0. 00	0. 00	0. 00	0. 00	4. 39	5. 97	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 131. 0	0. 00	0. 00	0. 00	0. 00	4. 55	6. 25	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 132. 0	0. 00	0. 00	0. 00	0. 00	4. 66	6. 51	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 133. 0	0. 00	0. 00	0. 00	0. 09	4. 75	6. 79	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 134. 0	0. 00	0. 00	0. 00	0. 22	4. 81	7. 07	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 135. 0	0. 00	0. 00	0. 00	0. 25	4. 86	7. 32	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 136. 0	0. 00	0. 00	0. 00	0. 27	4. 94	7. 49	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 137. 0	0. 00	0. 00	0. 00	0. 37	4. 96	7. 72	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 138. 0	0. 00	0. 00	0. 00	0. 36	4. 96	7. 92	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 139. 0	0. 00	0. 00	0. 00	0. 43	4. 97	8. 07	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00
γ 140. 0	0. 00	0. 00	0. 00	0. 43	4. 90	8. 19	0. 00	0. 00	0. 00	0. 00	0. 00	0. 00

# IES Indoor Report

## Candela Tabulation - (Cont.)

V/H	C0.0	C30.0	C60.0	C90.0	C120.0	C150.0	C180.0	C210.0	C240.0	C270.0	C300.0	C330.0
γ 141.0	0.00	0.00	0.00	0.46	4.80	8.33	0.00	0.00	0.00	0.00	0.00	0.00
γ 142.0	0.00	0.00	0.00	0.46	4.75	8.42	0.00	0.00	0.00	0.00	0.00	0.00
γ 143.0	0.00	0.00	0.00	0.45	4.69	8.49	0.00	0.00	0.00	0.00	0.00	0.00
γ 144.0	0.00	0.00	0.00	0.42	4.57	8.53	0.00	0.00	0.00	0.00	0.00	0.00
γ 145.0	0.00	0.00	0.00	0.43	4.54	8.64	0.00	0.00	0.00	0.00	0.00	0.00
γ 146.0	0.00	0.00	0.00	0.45	4.39	8.73	0.00	0.00	0.00	0.00	0.00	0.00
γ 147.0	0.00	0.00	0.00	0.40	4.29	8.67	0.00	0.00	0.00	0.00	0.00	0.00
γ 148.0	0.00	0.00	0.00	0.38	4.22	8.71	0.00	0.00	0.00	0.00	0.00	0.00
γ 149.0	0.00	0.00	0.00	0.34	4.00	8.71	0.00	0.00	0.00	0.00	0.00	0.00
γ 150.0	0.00	0.00	0.00	0.34	3.98	8.65	0.00	0.00	0.00	0.00	0.00	0.00
γ 151.0	0.00	0.00	0.00	0.31	3.85	8.66	0.00	0.00	0.00	0.00	0.00	0.00
γ 152.0	0.00	0.00	0.00	0.22	3.70	8.60	0.00	0.00	0.00	0.00	0.00	0.00
γ 153.0	0.00	0.00	0.00	0.17	3.52	8.56	0.00	0.00	0.00	0.00	0.00	0.00
γ 154.0	0.00	0.00	0.00	0.13	3.37	8.49	0.00	0.00	0.00	0.00	0.00	0.00
γ 155.0	0.00	0.00	0.00	0.09	3.18	8.34	0.00	0.00	0.00	0.00	0.00	0.00
γ 156.0	0.00	0.00	0.00	0.00	3.08	8.24	0.00	0.00	0.00	0.00	0.00	0.00
γ 157.0	0.00	0.00	0.00	0.06	2.91	8.12	0.00	0.00	0.00	0.00	0.00	0.00
γ 158.0	0.00	0.00	0.00	0.00	2.84	8.06	0.00	0.00	0.00	0.00	0.00	0.00
γ 159.0	0.00	0.00	0.00	0.00	2.67	7.88	0.00	0.00	0.00	0.00	0.00	0.00
γ 160.0	0.00	0.00	0.00	0.00	2.52	7.80	0.00	0.00	0.00	0.00	0.00	0.00
γ 161.0	0.00	0.00	0.00	0.00	2.47	7.72	0.00	0.00	0.00	0.00	0.00	0.00
γ 162.0	0.00	0.00	0.00	0.00	2.38	7.51	0.00	0.00	0.00	0.00	0.00	0.00
γ 163.0	0.00	0.00	0.00	0.00	2.36	7.35	0.00	0.00	0.00	0.00	0.00	0.00
γ 164.0	0.00	0.00	0.00	0.00	2.27	7.23	0.00	0.00	0.00	0.00	0.00	0.00
γ 165.0	0.00	0.00	0.00	0.00	2.17	7.05	0.00	0.00	0.00	0.00	0.00	0.00
γ 166.0	0.00	0.00	0.00	0.00	1.98	6.88	0.00	0.00	0.00	0.00	0.00	0.00
γ 167.0	0.00	0.00	0.00	0.00	1.93	6.70	0.00	0.00	0.00	0.00	0.00	0.00
γ 168.0	0.00	0.00	0.00	0.01	1.86	6.47	0.00	0.00	0.00	0.00	0.00	0.00
γ 169.0	0.00	0.00	0.00	0.00	1.80	6.33	0.00	0.00	0.00	0.00	0.00	0.00
γ 170.0	0.00	0.03	0.00	0.00	1.74	6.09	0.00	0.00	0.00	0.00	0.00	0.08
γ 171.0	0.00	0.05	0.00	0.00	1.58	5.92	0.00	0.00	0.00	0.00	0.00	0.43
γ 172.0	0.00	0.07	0.00	0.00	1.54	5.62	0.00	0.00	0.00	0.00	0.00	0.75