



Indoor Luminaire Photometric Data

Description Information

Luminary Name: 55252		Lum. Catalog:	Test ID:
Lamp Name:		Lamp Catalog:	Test Date: 2024/03/07
Manufacture:		Shld. Ang(°):	Test Machine:GON-2000
Test Lab:		Frequency (Hz):50	Lamp CCT(K): 3000 Ra: 80
Lum. Size(W*L*H):0.045m*1.000m*0.044m		Lum. Area(m2):0.089	Lum. W(kg): 0.000
Test System: C, γ	Test Step: C=30.0 γ=1.0	Temp. (°C): 25	Humidity(%): 50.0


Character Parameter

Lamp Speciality Parameter		Luminaire Speciality Parameter	
Rated Flux(lm): 350.190	Luminary Flux(lm): 350.189	Field Angle(10%Imax): 60.9(°)	
Rated Power(W): 5	Luminary Efficiency: 100.00%	Down Lumens&Percent: 350.189lm 100.00%	
Rated Voltage(V): 220	Luminary EER(lm/W): 77.596	Up Lumens&Percent: 0.000lm 0.00%	
Tested Power(W): 4.513	Max. Candela(cd): 857.860	S/MH: C0_a180=0.544 C90_270=0.544	
Lamps' Inside: 1	Max Cand@Ang. (°): C=180.0 γ=2.0	CIE Type: Semi-Direct	
Tested Electrics(V, A, pf):220.9, 0.041, 0.497	Beam Angle(50%Imax): 32.4(°)	ErP Φ use(90°): 337.548lm	
Lamp Size(W*L*H):0.045m*1.000m*0.044m	Left=-12.6°, Right=19.8°	IRF(%): 531.264	



2D Plane Light Intensity Distribution Curve


Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date:2024/03/07



3D Light Intensity Distribution Modal

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date:2024/03/07

3D Light Intensity Distribution Modal



Photometric Filename:DL-5W-COB-0500-BH-36D.IES

Zone(γ)	Zone Flux (1m)	Sums Flux (1m)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (1m)	Sums Flux (1m)	Zone%Lamp	Sums%Lamp
0.0-1.0	0.81	0.81	0.23	0.23	47.0-48.0	1.51	342.86	0.43	97.91
1.0-2.0	2.41	3.22	0.69	0.92	48.0-49.0	1.36	344.22	0.39	98.30
2.0-3.0	3.98	7.19	1.14	2.05	49.0-50.0	1.21	345.43	0.35	98.64
3.0-4.0	5.49	12.69	1.57	3.62	50.0-51.0	1.02	346.45	0.29	98.93
4.0-5.0	6.95	19.63	1.98	5.61	51.0-52.0	0.82	347.27	0.23	99.17
5.0-6.0	8.32	27.95	2.38	7.98	52.0-53.0	0.65	347.92	0.19	99.35
6.0-7.0	9.58	37.54	2.74	10.72	53.0-54.0	0.55	348.47	0.16	99.51
7.0-8.0	10.72	48.26	3.06	13.78	54.0-55.0	0.48	348.95	0.14	99.65
8.0-9.0	11.71	59.96	3.34	17.12	55.0-56.0	0.41	349.36	0.12	99.76
9.0-10.0	12.52	72.49	3.58	20.70	56.0-57.0	0.35	349.71	0.10	99.86
10.0-11.0	13.17	85.65	3.76	24.46	57.0-58.0	0.27	349.98	0.08	99.94
11.0-12.0	13.64	99.29	3.90	28.35	58.0-59.0	0.15	350.14	0.04	99.98
12.0-13.0	13.95	113.24	3.98	32.34	59.0-60.0	0.05	350.19	0.01	100.00
13.0-14.0	14.08	127.32	4.02	36.36	60.0-61.0	0.00	350.19	0.00	100.00
14.0-15.0	14.02	141.33	4.00	40.36	61.0-62.0	0.00	350.19	0.00	100.00
15.0-16.0	13.79	155.12	3.94	44.30	62.0-63.0	0.00	350.19	0.00	100.00
16.0-17.0	13.41	168.53	3.83	48.12	63.0-64.0	0.00	350.19	0.00	100.00
17.0-18.0	12.91	181.44	3.69	51.81	64.0-65.0	0.00	350.19	0.00	100.00
18.0-19.0	12.33	193.76	3.52	55.33	65.0-66.0	0.00	350.19	0.00	100.00
19.0-20.0	11.68	205.44	3.34	58.67	66.0-67.0	0.00	350.19	0.00	100.00
20.0-21.0	11.00	216.44	3.14	61.81	67.0-68.0	0.00	350.19	0.00	100.00
21.0-22.0	10.31	226.75	2.94	64.75	68.0-69.0	0.00	350.19	0.00	100.00
22.0-23.0	9.62	236.37	2.75	67.50	69.0-70.0	0.00	350.19	0.00	100.00
23.0-24.0	8.95	245.31	2.56	70.05	70.0-71.0	0.00	350.19	0.00	100.00
24.0-25.0	8.31	253.62	2.37	72.42	71.0-72.0	0.00	350.19	0.00	100.00
25.0-26.0	7.69	261.31	2.20	74.62	72.0-73.0	0.00	350.19	0.00	100.00
26.0-27.0	7.11	268.42	2.03	76.65	73.0-74.0	0.00	350.19	0.00	100.00
27.0-28.0	6.56	274.99	1.87	78.53	74.0-75.0	0.00	350.19	0.00	100.00
28.0-29.0	6.06	281.05	1.73	80.26	75.0-76.0	0.00	350.19	0.00	100.00
29.0-30.0	5.60	286.65	1.60	81.86	76.0-77.0	0.00	350.19	0.00	100.00
30.0-31.0	5.19	291.84	1.48	83.34	77.0-78.0	0.00	350.19	0.00	100.00
31.0-32.0	4.83	296.67	1.38	84.72	78.0-79.0	0.00	350.19	0.00	100.00
32.0-33.0	4.51	301.18	1.29	86.00	79.0-80.0	0.00	350.19	0.00	100.00
33.0-34.0	4.23	305.40	1.21	87.21	80.0-81.0	0.00	350.19	0.00	100.00
34.0-35.0	3.97	309.38	1.13	88.35	81.0-82.0	0.00	350.19	0.00	100.00
35.0-36.0	3.74	313.12	1.07	89.41	82.0-83.0	0.00	350.19	0.00	100.00
36.0-37.0	3.53	316.							

IES Indoor Report


Photometric Filename:DL-5W-COB-0500-BH-36D.IES

Zonal Flux Tabulation - (Cont.)

Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp	Zone(γ)	Zone Flux (lm)	Sums Flux (lm)	Zone%Lamp	Sums%Lamp
94.0-95.0	0.00	350.19	0.00	100.00	141.0-142.0	0.00	350.19	0.00	100.00
95.0-96.0	0.00	350.19	0.00	100.00	142.0-143.0	0.00	350.19	0.00	100.00
96.0-97.0	0.00	350.19	0.00	100.00	143.0-144.0	0.00	350.19	0.00	100.00
97.0-98.0	0.00	350.19	0.00	100.00	144.0-145.0	0.00	350.19	0.00	100.00
98.0-99.0	0.00	350.19	0.00	100.00	145.0-146.0	0.00	350.19	0.00	100.00
99.0-100.0	0.00	350.19	0.00	100.00	146.0-147.0	0.00	350.19	0.00	100.00
100.0-101.0	0.00	350.19	0.00	100.00	147.0-148.0	0.00	350.19	0.00	100.00
101.0-102.0	0.00	350.19	0.00	100.00	148.0-149.0	0.00	350.19	0.00	100.00
102.0-103.0	0.00	350.19	0.00	100.00	149.0-150.0	0.00	350.19	0.00	100.00
103.0-104.0	0.00	350.19	0.00	100.00	150.0-151.0	0.00	350.19	0.00	100.00
104.0-105.0	0.00	350.19	0.00	100.00	151.0-152.0	0.00	350.19	0.00	100.00
105.0-106.0	0.00	350.19	0.00	100.00	152.0-153.0	0.00	350.19	0.00	100.00
106.0-107.0	0.00	350.19	0.00	100.00	153.0-154.0	0.00	350.19	0.00	100.00
107.0-108.0	0.00	350.19	0.00	100.00	154.0-155.0	0.00	350.19	0.00	100.00
108.0-109.0	0.00	350.19	0.00	100.00	155.0-156.0	0.00	350.19	0.00	100.00
109.0-110.0	0.00	350.19	0.00	100.00	156.0-157.0	0.00	350.19	0.00	100.00
110.0-111.0	0.00	350.19	0.00	100.00	157.0-158.0	0.00	350.19	0.00	100.00
111.0-112.0	0.00	350.19	0.00	100.00	158.0-159.0	0.00	350.19	0.00	100.00
112.0-113.0	0.00	350.19	0.00	100.00	159.0-160.0	0.00	350.19	0.00	100.00
113.0-114.0	0.00	350.19	0.00	100.00	160.0-161.0	0.00	350.19	0.00	100.00
114.0-115.0	0.00	350.19	0.00	100.00	161.0-162.0	0.00	350.19	0.00	100.00
115.0-116.0	0.00	350.19	0.00	100.00	162.0-163.0	0.00	350.19	0.00	100.00
116.0-117.0	0.00	350.19	0.00	100.00	163.0-164.0	0.00	350.19	0.00	100.00
117.0-118.0	0.00	350.19	0.00	100.00	164.0-165.0	0.00	350.19	0.00	100.00
118.0-119.0	0.00	350.19	0.00	100.00	165.0-166.0	0.00	350.19	0.00	100.00
119.0-120.0	0.00	350.19	0.00	100.00	166.0-167.0	0.00	350.19	0.00	100.00
120.0-121.0	0.00	350.19	0.00	100.00	167.0-168.0	0.00	350.19	0.00	100.00
121.0-122.0	0.00	350.19	0.00	100.00	168.0-169.0	0.00	350.19	0.00	100.00
122.0-123.0	0.00	350.19	0.00	100.00	169.0-170.0	0.00	350.19	0.00	100.00
123.0-124.0	0.00	350.19	0.00	100.00	170.0-171.0	0.00	350.19	0.00	100.00
124.0-125.0	0.00	350.19	0.00	100.00	171.0-172.0	0.00	350.19	0.00	100.00
125.0-126.0	0.00	350.19	0.00	100.00	172.0-173.0	0.00	350.19	0.00	100.00
126.0-127.0	0.00	350.19	0.00	100.00	173.0-174.0	0.00	350.19	0.00	100.00
127.0-128.0	0.00	350.19	0.00	100.00	174.0-175.0	0.00	350.19	0.00	100.00
128.0-129.0	0.00	350.19	0.00	100.00	175.0-176.0	0.00	350.19	0.00	100.00
129.0-130.0	0.00	350.19	0.00	100.00	176.0-177.0	0.00	350.19	0.00	100.00
130.0-131.0	0.00	350.19	0.00	100.00	177.0-178.0	0.00	350.19	0.00	100.00
131.0-132.0	0.00	350.19	0.00	100.00	178.0-179.0	0.00	350.19	0.00	100.00
132.0-133.0	0.00	350.19	0.00	100.00	179.0-180.0	0.00	350.19	0.00	100.00
133.0-134.0	0.00	350.19	0.00	100.00					
134.0-135.0	0.00	350.19	0.00	100.00					
135.0-136.0	0.00	350.19	0.00	100.00					
136.0-137.0	0.00	350.19	0.00	100.00					
137.0-138.0	0.00	350.19	0.00	100.00					
138.0-139.0	0.00	350.19	0.00	100.00					
139.0-140.0	0.00	350.19	0.00	100.00					
140.0-141.0	0.00	350.19	0.00	100.00					

Rectangle ISO Lighting Intensity Diagram

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07




Maximum Light Intensity(cd): 857.86
Maximum Cand.@Angle: H=-2.0°,V=0.0°

Photometric Filename:DL-5W-COB-0500-BH-36D.IES

Plane ISO-Illuminance Diagram

Lum. Name: 55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07

Plane ISO-Illuminance Curve



Working Plane Maximum Illuminance(lx): 95.14


Working Plane Maximum Illuminance Position(d/h):H0.0 V-0.0

Photometric Filename:DL-5W-COB-0500-BH-36D.IES

3D Plane ISO Illuminance Diagram

Lum. Name: 55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07

3D Plane Illuminance Modal



Space ISO Illuminance Diagram

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07


Space ISO Illuminance Curve



Space Plane Maximum Illuminance and @Angle:845.03lx,0.0deg
Plane Maximum Lighting Intensity and @Angle:845.182cd,0deg

Illuminance-Distance Diagram

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07



Indoor Luminance Limiting Curves

Lum. Name:55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07


Glare Grade Table

GI	Quality	Using Illuminance							
1.15	A	2000	1000	500	<=300				
1.5	B		2000	1000	500	<=300			
1.85	C			2000	1000	500	<=300		
2.2	D				2000	1000	500	<=300	
2.55	E	a				2000	1000	500	<=300
			b	c	d	e	f	g	h

Luminance Table

Gama (deg)	45	50	55	60	65	70	75	80	85
C0	237	115	0	0	0	0	0	0	0
C90	241	117	0	0	0	0	0	0	0

Luminance Limiting Curve




Luminous Size:Length(m)=1.000Width(m)=0.045Height(m)=0.044Area(m^2)=0.089000

Luminous Type:Without Luminous Side

Luminous Curves:C0-C180 Color: C90-C270 Color:

Indoor Budgetary Estimate Table

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07



Indoor Coefficient of Utilization Table

Lum. Name:55252	Lum. Catelog:	Test ID:
Lamp Name:	Lamp Catelog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07

Coefficients of Utilization – Zonal Cavity Method																		
Coef.	Effective Floor Cavity Reflectance RFC=0.20																	
RhoCC (%)	80				70				50			30			10			0
RhoW (%)	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR	Coefficient of Utilization(%)																	
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	112	109	107	112	110	108	106	106	104	103	102	101	99	98	98	97	95
2	109	105	101	98	107	103	100	97	100	98	95	97	95	93	95	93	91	90
3	105	99	95	91	103	98	94	91	95	92	89	93	90	88	91	88	86	85
4	100	94	89	85	99	93	88	85	91	87	84	89	85	83	87	84	82	81
5	96	89	84	80	95	88	83	80	86	82	79	85	81	78	83	80	78	76
6	92	85	79	76	91	84	79	75	82	78	75	81	77	74	80	77	74	73
7	89	81	75	72	87	80	75	72	79	74	71	78	74	71	77	73	71	69
8	85	77	72	68	84	77	72	68	76	71	68	75	71	68	74	70	67	66
9	82	74	69	65	81	73	68	65	72	68	65	72	68	65	71	67	65	63
10	79	71	66	62	78	70	66	62	70	65	62	69	65	62	68	65	62	61

Unified Glare Rating Table

Lum. Name: 55252	Lum. Catalog:	Test ID:
Lamp Name:	Lamp Catalog:	Test Lab:
Manufacture:	Test Machine:GON-2000	Test Date: 2024/03/07

Unified Glare Rating Table

Ceiling RCC		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
Wall RW		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
Floor RFC		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room Size		Vewed crosswise					Vewed endwise				
X=2H	Y=2H	2.2	3.1	2.5	3.5	3.8	-0.3	0.6	0.0	0.9	1.3
	Y=3H	2.0	2.8	2.4	3.2	3.5	-0.5	0.3	-0.1	0.7	1.0
	Y=4H	1.9	2.7	2.3	3.0	3.4	-0.6	0.1	-0.2	0.5	0.9
	Y=6H	1.8	2.5	2.2	2.9	3.3	-0.7	-0.0	-0.3	0.3	0.7
	Y=8H	1.7	2.4	2.1	2.8	3.2	-0.8	-0.1	-0.4	0.3	0.7
	Y=12H	1.6	2.3	2.1	2.7	3.1	-0.9	-0.2	-0.4	0.2	0.6
X=4H	Y=2H	1.9	2.7	2.3	3.1	3.5	-0.6	0.1	-0.2	0.5	0.9
	Y=3H	1.7	2.4	2.1	2.8	3.2	-0.8	-0.2	-0.4	0.2	0.6
	Y=4H	1.6	2.2	2.0	2.6	3.0	-1.0	-0.4	-0.5	0.0	0.5
	Y=6H	1.5	2.0	1.9	2.4	2.9	-1.1	-0.6	-0.6	-0.2	0.3
	Y=8H	1.4	1.9	1.9	2.3	2.8	-1.2	-0.7	-0.7	-0.3	0.2
	Y=12H	1.3	1.7	1.8	2.2	2.7	-1.2	-0.8	-0.7	-0.4	0.1
X=8H	Y=4H	1.4	1.9	1.9	2.3	2.8	-1.2	-0.7	-0.7	-0.3	0.2
	Y=6H	1.3	1.6	1.8	2.1	2.6	-1.3	-0.9	-0.8	-0.4	0.1
	Y=8H	1.2	1.5	1.7	2.0	2.5	-1.4	-1.0	-0.8	-0.5	-0.0
	Y=12H	1.1	1.4	1.7	1.9	2.5	-1.4	-1.1	-0.9	-0.6	-0.1
X=12H	Y=4H	1.3	1.7	1.8	2.2	2.7	-1.2	-0.8	-0.7	-0.4	0.1
	Y=6H	1.2	1.5	1.7	2.0	2.5	-1.4	-1.0	-0.8	-0.6	-0.0
	Y=8H	1.1	1.4	1.7	1.9	2.5	-1.4	-1.1	-0.9	-0.6	-0.1
Variations with the objverver position at spacings											
S=1.0H		0.0/0.0					0.0/0.0				
S=1.5H		0.0/0.0					0.0/0.0				
S=2.0H		0.0/0.0					0.0/0.0				
Reduced UGR Table:											
Nordic Standard Table:		BK0					BK0				
Correction Value		0.0					0.0				

o the CIE Pub.117, data has been corrected, refers to the lamp's lumens 8.2flm.

IES Indoor Report

Photometric Filename:DL-5W-COB-0500-BH-36D.IES

Candela Tabulation

V/H	C0. 0	C30. 0	C60. 0	C90. 0	C120. 0	C150. 0	C180. 0	C210. 0	C240. 0	C270. 0	C300. 0	C330. 0
γ 0. 0	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03	845. 03
γ 1. 0	845. 18	847. 90	838. 11	830. 99	822. 71	825. 30	855. 72	854. 13	850. 34	846. 42	841. 95	843. 27
γ 2. 0	833. 00	836. 72	824. 82	816. 28	805. 71	807. 90	857. 86	854. 95	851. 88	849. 41	846. 32	846. 83
γ 3. 0	815. 32	821. 02	807. 51	796. 93	783. 18	785. 40	857. 14	854. 26	852. 34	850. 62	848. 91	848. 78
γ 4. 0	792. 15	800. 01	783. 54	772. 78	756. 65	758. 78	856. 02	853. 79	852. 15	851. 36	850. 16	849. 68
γ 5. 0	763. 21	772. 27	754. 11	743. 33	726. 46	728. 42	855. 42	853. 77	852. 70	851. 93	850. 87	850. 46
γ 6. 0	727. 49	740. 41	719. 74	709. 75	692. 24	693. 79	853. 50	852. 04	851. 96	850. 51	850. 45	849. 93
γ 7. 0	685. 64	702. 93	679. 84	670. 49	652. 77	654. 80	849. 86	849. 08	849. 14	847. 50	847. 51	847. 86
γ 8. 0	640. 59	661. 00	636. 42	627. 42	609. 60	612. 46	842. 26	840. 78	842. 39	839. 98	842. 55	842. 95
γ 9. 0	593. 50	616. 24	590. 80	582. 12	564. 46	567. 95	828. 81	825. 80	829. 86	827. 31	832. 81	833. 44
γ 10. 0	545. 55	567. 78	543. 61	536. 27	518. 45	522. 48	809. 27	806. 84	814. 03	810. 37	818. 67	818. 20
γ 11. 0	498. 95	518. 80	496. 52	490. 83	472. 79	476. 74	784. 98	783. 10	793. 88	788. 83	799. 71	797. 02
γ 12. 0	454. 91	471. 93	451. 23	446. 28	428. 87	433. 11	755. 89	755. 20	767. 77	761. 59	775. 28	770. 65
γ 13. 0	413. 18	427. 59	408. 09	403. 66	387. 32	392. 12	722. 83	723. 35	736. 52	730. 49	745. 32	738. 83
γ 14. 0	373. 22	385. 66	366. 95	363. 34	348. 01	352. 45	685. 71	685. 25	699. 69	694. 34	709. 88	701. 71
γ 15. 0	334. 77	345. 39	328. 24	325. 74	311. 46	315. 18	643. 66	641. 55	657. 83	653. 21	669. 83	659. 70
γ 16. 0	298. 43	307. 63	292. 23	291. 26	276. 98	280. 54	598. 83	595. 34	613. 29	609. 01	625. 64	614. 43
γ 17. 0	264. 81	273. 24	259. 84	259. 70	245. 66	248. 99	552. 64	547. 64	566. 37	562. 25	579. 06	567. 29
γ 18. 0	234. 57	242. 17	230. 85	230. 73	217. 67	220. 45	505. 47	500. 78	518. 96	515. 29	531. 44	519. 60
γ 19. 0	207. 50	214. 07	204. 17	204. 50	192. 28	194. 39	461. 01	455. 64	473. 06	469. 24	484. 54	472. 89
γ 20. 0	183. 31	188. 71	180. 07	180. 55	169. 68	171. 12	418. 55	412. 86	429. 07	424. 43	438. 94	428. 10
γ 21. 0	161. 99	166. 22	158. 73	159. 44	149. 70	150. 74	377. 83	372. 94	387. 77	382. 68	395. 92	385. 75
γ 22. 0	143. 23	146. 64	140. 44	141. 14	132. 35	133. 35	338. 71	334. 87	348. 91	343. 77	355. 49	346. 17
γ 23. 0	127. 18	130. 19	124. 67	125. 64	117. 70	118. 46	302. 82	299. 61	312. 61	307. 57	318. 23	309. 44
γ 24. 0	113. 92	116. 51	112. 00	112. 78	105. 70	106. 36	269. 33	267. 27	279. 01	274. 11	283. 63	276. 24
γ 25. 0	102. 79	104. 86	101. 17	101. 75	95. 45	96. 18	238. 50	237. 27	247. 82	243. 49	252. 06	245. 91
γ 26. 0	93. 24	94. 85	91. 92	92. 29	86. 76	87. 53	210. 69	209. 67	219. 20	215. 91	223. 11	218. 13
γ 27. 0	85. 10	86. 43	83. 92	84. 37	79. 40	79. 92	185. 96	184. 57	193. 43	190. 79	197. 01	192. 82
γ 28. 0	77. 90	79. 11	77. 06	77. 59	73. 16	73. 57	163. 95	162. 28	170. 54	168. 48	173. 72	170. 32
γ 29. 0	71. 60	72. 95	71. 08	71. 66	67. 25	67. 70	144. 82	143. 05	150. 48	148. 96	153. 35	150. 50
γ 30. 0	65. 58	66. 84	65. 17	65. 72	61. 75	62. 23	128. 56	126. 60	133. 34	132. 19	135. 77	133. 52
γ 31. 0	60. 05	61. 35	59. 86	60. 39	56. 97	57. 27	114. 79	112. 97	118. 89	117. 96	120. 81	119. 07
γ 32. 0	55. 30	56. 53	55. 30	55. 81	52. 69	52. 82	103. 28	101. 67	106. 80	105. 94	108. 11	107. 13
γ 33. 0	50. 84	52. 11	51. 12	51. 45	48. 64	48. 90	93. 69	92. 09	96. 71	95. 82	97. 31	96. 63
γ 34. 0	46. 97	48. 12	47. 32	47. 61	44. 92	45. 16	85. 36	83. 79	88. 06	87. 04	88. 13	87. 77
γ 35. 0	43. 22	44. 37	43. 54	43. 92	41. 40	41. 72	78. 37	77. 01	80. 53	79. 65	80. 29	80. 17
γ 36. 0	39. 82	40. 78	40. 22	40. 54	38. 16	38. 65	72. 13	70. 95	74. 25	73. 36	73. 66	73. 69
γ 37. 0	36. 63	37. 66	37. 22	37. 48	35. 13	35. 76	66. 11	65. 22	68. 08	67. 11	67. 56	67. 40
γ 38. 0	33. 60	34. 62	34. 10	34. 36	32. 33	32. 78	60. 72	60. 06	62. 45	61. 55	61. 82	61. 67
γ 39. 0	30. 58	31. 62	31. 25	31. 52	29. 64	30. 08	55. 98	55. 45	57. 59	56. 76	56. 81	56. 88
γ 40. 0	27. 61	28. 90	28. 48	28. 81	27. 17	27. 47	51. 65	51. 10	53. 22	52. 40	52. 55	52. 34
γ 41. 0	24. 80	26. 34	25. 91	26. 30	24. 80	25. 01	47. 80	47. 21	49. 26	48. 59	48. 63	48. 35
γ 42. 0	22. 27	23. 89	23. 43	23. 74	22. 47	22. 72	44. 09	43. 49	45. 40	44. 81	45. 02	44. 52
γ 43. 0	19. 65	20. 98	19. 84	20. 55	18. 54	18. 71	40. 80	39. 93	41. 76	41. 25	41. 47	40. 92
γ 44. 0	17. 00	17. 67	17. 03	17. 43	15. 93	16. 08	37. 55	36. 64	38. 62	38. 03	38. 14	37. 58
γ 45. 0	14. 91	15. 30	14. 67	15. 14	13. 73	13. 90	34. 52	33. 45	35. 41	34. 79	35. 02	34. 32
γ 46. 0	12. 85	13. 26	12. 69	13. 08	11. 84	11. 98	31. 84	30. 41	32. 31	31. 57	31. 87	31. 28

IES Indoor Report

Candela Tabulation - (Cont.)

[illegible]

Photometric Filename:DL-5W-COB-0500-BH-36D.IES[illegible]

Photometric Filename:DL-5W-COB-0500-BH-36D.IES

Candela Tabulation - (Cont.)

[illegible]