



Product Service

# CERTIFICATE

No. B 121070 0003 Rev. 00

**Holder of Certificate:** ZHEJIANG PNTECH TECHNOLOGY CO.,  
LTD  
Zhongyi Road, Gulin Town  
Haishu District  
315000 Ningbo City  
PEOPLE'S REPUBLIC OF CHINA

**Certification Mark:**

**Product:** Connector  
**Model(s):** Connectors for Photovoltaic Systems  
PV004

**Parameters:** Rated Voltage: 1000VDC  
Rated Current: 30A  
Class (IEC 61140): II  
Degree of Protection: IP65/IP67  
Ambient Temperature: -40°C ~ +85°C

**Tested according to:** IEC 62852:2014  
IEC 62852:2014/AMD1:2020  
EN 62852:2015/A1:2020

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert)

**Test report no.:** 704071733202-01

**Valid until:** 2028-05-17

**Date,** 2023-05-19

( Yaqun Alex Liu )



CONTACT US

B 121070 0003 REV. 00

DEUTSCH

ENGLISH

---

<b>No.</b>	B 121070 0003 Rev. 00
<b>Type</b>	Certification Marks
<b>Type Name</b>	Type Tested Certificate
<b>Certification Body</b>	TÜV SÜD Product Service GmbH, Ridlerstr. 65, 80339 Munich, Germany
<b>Holder of Certificate</b>	ZHEJIANG PNTECH TECHNOLOGY CO., LTD Zhongyi Road, Gulin Town Haishu District 315000 Ningbo City People's Republic of China
<b>Product Model(s)</b>	Connector PV004
<b>Tested according to</b>	EN 62852:2015/A1:2020, IEC 62852:2014, IEC 62852:2014/AMD1:2020
<b>Date of Issue</b>	2023-05-19
<b>Status</b>	Valid

**CLOSE**