

# ADW300 Wireless Metering Meter

## Installation and Use Manual V1. 2

Contact: Shelly Zhang E-mail: shelly@acrel.cn Mobile: 0086 18702111813 Whatsapp: 0086 18702111813

Website: www.acrel-electric.co.za

# **Declaration**

The copyright is the property of Acrel. Any information in any paragraph or section cannot be extracted, copied or otherwise reproduced or propagated. Otherwise offenders shall take all consequences.

All rights are reserved.

Acrel reserves the right to modify the product specifications herein without notification. Please consult the local agent about the latest specifications before placing a purchase order.

# **Contents**


Declaration	1
1 Overview	3
2 Product model and specification	3
2.1 Naming Rules	3
2.2 Functional Characteristics	3
3 Technical parameter	4
3.1 Electrical performance	4
3.2 Work environment	5
4 Dimension and installing description	5
4.1 Dimension (Unit: mm)	5
4.2 Interfaces of Auxiliary power supply, Communication and Pulse	7
4.3 Interfaces of DI and DO	7
4.4 Interfaces of Temperature and Aftercurrent	8
4.5 Instruction of wiring	8
5 Main functions and features	11
5.1 Measurement	11
5.2 Metering	11
5.3 Tiered pricing	11
5.4 Demand	12
5.5 Historical data	12
5.6 Digital input/ output	12
5.7 Wireless Communication Function	12
6 Communication description	12
6.1 Protocol	12
6.2 MODBUS	13
6.3 Settings of Alarm	19
6.4 Historical Data Memory	21
6.5 Record of extreme value and occurrence time	23
7 Common troubleshooting	25
7.1 RS485 networking communication failure	
7.2 Wireless communication failure of instrumentation	26

#### 1 Overview

ADW300 Wireless Metering Meter is mainly used to metering three phase active energy on low voltage network. The product boasts of advantages including compact size, high precision, rich features. According to different requirements, there are many communications functions like RS485 communication, WIFI, NB, 4G, adding the new current sampling mode using external transformer. It can be flexibly installed in the distribution box to achieve sub-item electric energy metering, operation and maintenance supervision or power monitoring requirements for different regions and different loads.

### 2 Product model and specification

#### 2.1 Naming Rules



#### 2.2 Functional Characteristics

Chart 1 Functions of ADW300

Functions	Description
Display mode	LCD
Energy metering	Active kWh (positive and negative), quadrant reactive

	power energy
Electrical measurement	U, I, P, Q, S, PF, F
Harmonic function	THDv, Harmonic on 2nd-31st
Pulse output	Active pulse output
Three-phase unbalance degree	Voltage unbalance,current unbalance
Temperature measurement	Temperature of A/B/C/N (Alternate configuration:T)
DI/DO	4DI,2DO (Alternate configuration:K)
Aftercurrent	One-way aftercurrent (Alternate configuration:L)
LED display	Pulse LED display
External current transformer	External open type current transformer
External current transformer	(Alternate configuration:W)
Electrical parameter	Undervoltage, undercurrent, overcurrent, underload,
Electrical parameter	etc
	Infrared communication
	RS485 (Alternate configuration:C)
	Wireless transmission on 470MHz
Communication	(Alternate configuration:LR)
	WIFI(Alternate configuration:WF)
	NB-IOT(Alternate configuration:NB)
	4G (Alternate configuration:4G)

## 3 Technical parameter

## 3.1 Electrical performance

Chart 2 Electrical performance of ADW300

	Rated voltage	3×57.7/100V, 3×220/380V, 3×380/660V, 3×100V, 3×380V, 3 ×660V		
Voltage input	Reference	5011		
	frequency	50Hz		
	Consumption	<0.5VA (Each phase)		
	Input current	3×1(6)A; 3×1(6)A (ADW300W), 3×20(100)A (ADW300W)		
Current input	Start current	1‰ Ib (Class 0.5S), 4‰ Ib (Class 1)		
	Consumption	<1VA (Each phase)		
Auxiliary power	Power Supply	AC 85~265V		
Power consumption		<2W		
Measurement	Standard	IEC 62053-22:2003, IEC 62053-21:2003		

performance	Active energy accuracy	Class 0.5S (ADW300) , Class 1 (ADW300W)	
	Temperature accuracy	±2℃	
Pulse	Width of pulse	80±20ms	
1 uisc	Pulse constant 6400imp/kWh, 400imp/kWh		
	Wireless	Transmission on 470MHz and maximum distance in open space is 1km; 2G; NB; 4G	
Communication	Infrared communication	The constant baud rate is 1200	
	Interface	RS485(A、B)	
	Connection mode	Shielded twisted pair conductors	
	Protocol	MODBUS-RTU	

#### 3.2 Work environment

Chart 3 Work environment

Temperature range	Operating temperature	-20°C~55°C
remperature range	Storage temperature	-40°C~70°C
Humidity		≤95% (No condensation)
Altitude		<2000m

## 4 Dimension and installing description

## 4.1 Dimension (Unit: mm)

### (1) Dimensions of ADW300

Chart 4 Dimension of Residual Current transformer

Specifications	Current Rating	Inside diameters Φ mm	Outside diameters Φ mm	Weight
AKH-0.66L45	16~100A	45	76	0.18
AKH-0.66L80	100∼250A	80	120	0.42
AKH-0.66L100	250~400A	100	140	0.50
AKH-0.66L150	400~800A	150	190	1.32
AKH-0.66L200	800~1500A	200	240	1.94




Figure 1 Rendering of ADW300




Figure 2 Dimension of ADW300





Figure 3 Dimension of transformer HCT16K-FJ


### 4.2 Interfaces of Auxiliary power supply, Communication and Pulse




#### 4.3 Interfaces of DI and DO

The digital output is realized by relay for remote control and alarm output.


The digital input is realized by digital signal input. The meter has a built-in +12V working power supply so that it does not require external power supply. The meter collects the external break-make information with digital input module and displays it locally. The digital input not only collects and displays the local break-time information but also provides the remote transmission, i.e. remote communication, with RS485.






Digital output Digital input

### 4.4 Interfaces of Temperature and Aftercurrent




### 4.5 Instruction of wiring


There are four modes of connection like 3-phase 4-wire (current connected via CT), 3-phase 3-wire (current connected via CT), 3-phase 4-wire (current connected via PT and CT) and 3-phase -wire (current connected via PT and CT).




3-phase 4-wire (current connected via CT)



3-phase 3-wire (current connected via CT)




3-phase 4-wire (current connected via PT and CT)




3-phase 3-wire (current connected via PT and CT)

## 4.5.2 ADW300W



3-phase 4-wire



3-phase 3-wire

#### 5 Main functions and features

#### 5.1 Measurement

Measure all electrical parameters, including voltage U, current I, active power P, reactive power Q, apparent power S, power factor PF, Voltage imbalance, Current imbalance, frequency, 31st harmonic content and total harmonic content. The measured voltage U keeps one decimal place, the measured frequency F keeps two decimal places, the measured current I keeps three decimal places and the measured power P keeps four decimal places. Voltage imbalance and Current imbalance keeps four decimal places.

Example: U = 220.1V, f = 49.98HZ, I = 1.999A, P = 0.2199KW,  $\triangle = 0.00\%$ 

Supporting 4-way temperature measurement, range:  $-40 \sim 99 \,^{\circ}\text{C}$ , accuracy:  $\pm 2 \,^{\circ}\text{C}$ 

Supporting aftercurrent measurement, The initial range:  $0\sim1000\text{mA}$ , Range multiples can be set  $(1\sim60)$ 

#### 5.2 Metering

It can measure the current combined active power, positive active power, reverse active power, inductive reactive power, capacitive reactive power, as seen in the electric power.

#### 5.3 Tiered pricing

Two sets of time tables, a year can be divided into four time zones, each set of time

table can set 12 days, four rates (F1, F2, F3, F4 namely Sharp,peak,flat and valley).

#### 5.4 Demand

#### Demand-related concepts are listed as follows:

Demand	Average power measured during the demand period
Max. demand	Maximum amount of demand during a specified period of time
Sliding window time	A recurrence method to measure the demand from any time point during a period shorter than the demand period. The demand measured by this means is called sliding demand. The recurrence time is sliding window time.
Demand period	Time interval when the same average power is measured continuously, also known as window time

Measure eight maximum demands, i.e. A/B/C three-phase current ,positive active, negative active, inductive reactive , capacitive reactive and apparent power demands and the time of maximum demand.

#### 5.5 Historical data

Record the historical data on electricity consumption covering previous 12 months (including four quadrant and multi-rate tariff).

#### 5.6 Digital input/output

There are two-way Digital output and four-way Digital input. The Digital output is realized by relay for remote control and alarm output. The Digital input not only collects and displays the local break-time information but also provides the remote transmission, i.e. remote communication, with RS485.

#### 5.7 Wireless Communication Function

The ADW300 supports LORA, WIFI, NB, and 4G communications. Specific agreements on WIFI, NB and 4G communications can be obtained by contacting relevant personnel of our company.

### 6 Communication description

#### 6.1 Protocol

The meters adapt Modbus protocol. Please refer to the relevant standards for more information.

## 6.2 MODBUS

MODBUS-RTU protocol has 03H and 10H command to read and write registers respectively. The following chart is registers' address list:

1 7	Start	chart is registers addre			
Start Address	Address	77 ' 11	T .1	D/XX	NT /
(Hexadecimal)		Variable	Length	R/W	Notes
	(Decimal)				
0000Н	0	Address	2	R/W	1~247
					1: 1200bps
					2: 3400bps
0001H	1	Baud rate	2	R/W	3: 4800bps
					4: 9600bps
0002H	2	Spreading factor	2	R/W	6~12
000211	2	Spreading factor	2	10 11	0-45 (Communication with
0003H	3	Frequency channel setting	2	R/W	the same frequency host)
					High byte: 0-none, 1-even, 2-odd;
0004Н	4	High byte: parity mode, low	2	R/W	low byte: 0-1 stop Bit, 1-2 stop
000411	7	byte: stop Bit	2	IC/ VV	Bit
0005H	5		Day	served	Dit
0006H	6			constan	
0007Н	7			ght Tim	e
0008Н	8			ode	
0009H~000CH	9-12			served	
000DH	13		Current s	pecifica	tion
000EH	14			PT	
000FH	15			CT	
0010H	16	Tomas anothers of N. mboss	2	R	Int
		Temperature of N phase 2 R		unit 0.1°C	
0011H~0013H	17-19	Time, date (se	cond, min	ute, hou	r, day, month, year)
0014H	20	Voltage of A phase	2	R	
0015H	21	Voltage of B phase	2	R	Int
0016H	22	Voltage of C phase	2	R	Keep 1 decimal places
	22	V 1, 1 , A D	2	D	(The real value is the showed
0017H	23	Voltage between A-B	2	R	value divide 10.The following
0018H	24	Voltage between B-C	2	R	data all in this rule.)
0019H	25	Voltage between C-A	2	R	
001AH	26	Electricity of A phase	2	R	
001BH	27	Electricity of B phase	2	R	Int
001CH	28	Electricity of C phase	2	R	unit A Keep 2 decimal places
001DH	29	Vector sum of 3-phase	2	2 R	,
WIDH	29	current			
	L	<u>I</u>	I	1	

001EH	30	Active power of A phase	4	R	_
0020H	32	Active power of B phase	4	R	Int unit kW
0022H	34	Active power of C phase	4	R	Keep 3 decimal places
0024H	36	Total active power	4	R	
0026Н	38	Reactive power of A phase	4	R	
0028H	40	Reactive power of B phase	4	R	Int unit kVar
002AH	42	Reactive power of C phase	4	R	Keep 3 decimal places
002CH	44	Total reactive power	4	R	
002EH	46	Apparent power of A phase	4	R	_
0030H	48	Apparent power of B phase	4	R	Int unit kVA
0032H	50	Apparent power of C phase	4	R	Keep 3 decimal places
0034H	52	Total apparent power	4	R	1 - 1
0036Н	54	Power factor of A phase	2	R	
0037H	55	Power factor of B phase	2	R	Int
0038H	56	Power factor of C phase	2	R	Keep 3 decimal places
0039Н	57	Total power factor	2	R	
003AH	58	State of DI	2	R	Bit0: DI1 Bit1: DI2 Bit2: DI3 Bit3: DI4
003BH	59	Frequency of power	2	R	Int Keep 2 decimal places
003CH	60	Total energy consumption	4	R	
003EH	62	Forward active energy consumption	4	R	Int unit kWh
0040Н	64	Reversing active energy consumption	4	R	Keep 2 decimal places
0042Н	66	Forward reactive energy consumption	4	R	Int unit kVarh
0044Н	68	Reversing reactive energy consumption	4	R	Keep 2 decimal places
0046Н	70	Total energy consumption on A phase	4	R	Int
0048H	72	Forward active energy consumption on A phase	4	R	unit kWh
004AH	74	Reversing active energy consumption on A phase	4	R	Keep 2 decimal places
004CH	76	Forward reactive energy consumption on A phase	4	R	Int unit kVarh
004EH	78	Reversing reactive energy	4	R	Keep 2 decimal places

		consumption on A phase			
0050H	80	Total energy consumption on	4	R	
		B phase			Int
0052H	82	Forward active energy	4	R	unit kWh
0032П	82	consumption on B phase	4	K	
		Reversing active energy			Keep 2 decimal places
0054H	84	consumption on B phase	4	R	
		Forward reactive energy			
0056Н	86	consumption on B phase	4	R	Int
					unit kVarh
0058H	88	Reversing reactive energy	4	R	Keep 2 decimal places
		consumption on B phase			
005AH	90	Total energy consumption on	4	R	
0037111	70	C phase		IX.	14
005611	0.2	Forward active energy	4		Int
005CH	92	consumption on C phase	4	R	unit kWh
		Reversing active energy			Keep 2 decimal places
005EH	94	consumption on C phase	4	R	
0060H	96	Forward reactive energy	4	R	Int
		consumption on C phase			unit kVarh
0062Н	98	Reversing reactive energy	4	R	Keep 2 decimal places
000 <b>2</b> 11		consumption on C phase	·		
		Maximum forward active			Int
0064H	100		4	R	unit KW
		demand in current month			Keep 3 decimal places
0066H~0067H	102-103	Occur time	4	R	Minute, hour, day, month
					Int
0068H	104	Maximum reversing active	4	R	unit kVar
000611	104	demand in current month	4	4   K	
					Keep 3 decimal places
006AH~006BH	106-107	Occur time	4	R	Minute, hour, day, month
		Maximum forward reactive			Int
006CH	108	demand in current month	4	R	unit kVar
		demand in current month			Keep 3 decimal places
006EH~006FH	110-111	Occur time	4	R	Minute, hour, day, month
					Int
0070Н	112	Maximum reversing reactive	4	R	unit kVar
*******		demand in current month			Keep 3 decimal places
0072H~0073H	114-115	Occur time	4	R	Minute, hour, day, month
					wimute, nour, day, month
0074H	116	THDUa	2	R	
0075H	117	THDUb	2	R	Total distortion rate of voltage
0076Н	118	THDUc	2	R	and current on each phase
0077H	119	THDIa	2	R	Int
0078H	120	THDIb	2	R	Keep 2 decimal places
0079H	121	THDIc	2	R	
007AH	122	THUa(Harmonic on	2×30	R	Harmonic voltage on 2nd-31st
		=(112211101110 011			

		2-4 21-4			T.,, 4
		2nd-31st)			Int
0098Н	152	THUa(Harmonic on 2nd-31st)	2×30	R	Keep 2 decimal places
00B6H	182	THUb(Harmonic on 2nd-31st)	2×30	R	
00D4H	212	THUc(Harmonic on 2nd-31st)	2×30	R	
00F2H	242	THIa(Harmonic on 2nd-31st)	2×30	R	Harmonic current on 2nd-31st  Int
0110H	272	THIb(Harmonic on 2nd-31st)	2×30	R	Keep 2 decimal places
012EH	302	Fundamental voltage on A	2	R	
012FH	303	Fundamental voltage on B	2	R	
0130H	304	Fundamental voltage on C phase	2	R	Int
0131H	305	Harmonic voltage on A phase	2	R	unit V  Keep 1 decimal places
0132H	306	Harmonic voltage on B	2	R	
0133H	307	Harmonic voltage on C phase	2	R	
0134H	308	Fundamental current on A phase	2	R	
0135H	309	Fundamental current on B	2	R	
0136H	310	Fundamental current on C phase	2	R	Int
0137H	311	Harmonic current on A phase	2	R	unit A Keep 2 decimal places
0138H	312	Harmonic current on B	2	R	
0139Н	313	Harmonic current on C phase	2	R	
013AH	314	Fundamental active power on A phase	4	R	
013CH	316	Fundamental active power on B phase	4	R	Int unit kW
013EH	318	Fundamental active power on C phase	4	R	Keep 3 decimal places
0140H	320	Fundamental active power	4	R	
0142Н	322	Fundamental reactive power on A phase	4	R	Int unit kVar

0144H	324	Fundamental reactive power on B phase 4 R Keep 3 decimal		Keep 3 decimal places	
0146Н	326	Fundamental reactive power on C phase	4	R	
0148H	328	Fundamental reactive power	4	R	
014AH	330	Harmonic active power on A phase	4	R	
014CH	332	Harmonic active power on B phase	4	R	Int unit kW
014EH	334	Harmonic active power on C phase	4	R	Keep 3 decimal places
0150H	336	Harmonic active power	4	R	
0152H	338	Harmonic reactive power on A phase	4	R	
0154H	340	Harmonic reactive power on B phase	4	R	Int unit kVar
0156Н	342	Harmonic reactive power on C phase	4	R	Keep 3 decimal places
0158H	344	Harmonic reactive power	4	R	
015AH	346	Current forward active demand	4	R	Int unit kW
015CH	348	Current reversing active demand	4	R	Keep 3 decimal places
015EH	350	Current forward reactive demand	4	R	Int unit kVar
0160H	352	Current reversing reactive demand	4	R	Keep 3 decimal places
0162H	354	Voltage imbalance	2	R	Int
0163H	355	Current imbalance	2	R	unit 0.01%
0164H	356	Temperature on A phase	2	R	T.,
0165H	357	Temperature on B phase	2	R	Int unit 0.1°C
0166H	358	Temperature on C phase	2	R	unit 0.1 C
0167H	359	Time zone number/Time zone date: day	2	R/W	
0168H	360	Time zone date: month/Time zone number	2	R/W	
0169Н	361	Time zone date: day/ Time zone date: month	2	R/W	Time list
016AH	362	Time zone number/Time zone date: day	2	R/W	
016BH	363	Time zone date: month/Time	2	R/W	

		zone number			
016CH	364	Time zone date: day/ Time zone date: month	2	R/W	
016DH 	365-385	1-14 period of time Parameters setting	2	R/W	1# time list
0181H 0182H		information 1-14 period of time			
 0196Н	386-406	Parameters setting information	2	R/W	2# time list
0197Н	407	Current total spike active energy	4	R	
0199Н	409	Current total peak active energy	4	R	
019BH	411	Current total flat active energy	4	R	
019DH	413	Current total valley active energy	4	R	
019FH	415	Current total spike forward active energy	4	R	
01A1H	417	Current total peak forward active energy	4	R	Int unit kWh
01A3H	419	Current total flat forward active energy	4	R	Keep 2 decimal places
01A5H	421	Current total valley forward active energy	4	R	
01A7H	423	Current total spike reversing active energy	4	R	
01А9Н	425	Current total peak reversing active energy	4	R	
01ABH	427	Current total flat reversing active energy	4	R	
01ADH	429	Current total valley reversing active energy	4	R	
01AFH	431	Current total spike forward reactive energy	4	R	
01B1H	433	Current total peak forward reactive energy	4	R	
01B3H	435	Current total flat forward reactive energy	4	R	Int unit kVarh
01B5H	437	Current total valley forward reactive energy	4	R	Keep 2 decimal places
01B7H	439	Current total spike reversing reactive energy	4	R	
01B9H	441	Current total peak reversing	4	R	

		reactive energy			
01BBH	443	Current total flat reversing reactive energy	4	R	
01BDH	445	Current total valley reversing reactive energy	4	R	
01BFH	447	wireless signal strength	2	R	Int
					Int
01C1H	449	Aftercurrent	2	R	unit A
					Keep 3 decimal places
01C2H	450	DO1	2	R/W	Int
010211	730	DOI	2   R/W		Bit0 effective
01C3H	451	DO2	2	R/W	Int
VICSH	731	DO2	2	IV W	Bit0 effective

## 6.3 Settings of Alarm

Start Address (Hexadecimal)	Start Address (Decimal)	Variable	Length	R/W	Notes
01DOH	464	Alarm permission bits	2	R/W	Bit0: overvoltage alarm permission bits Bit1: undervoltage alarm permission bits Bit2: overcurrent alarm permission bits Bit3: undercurrent alarm permission bits Bit4: overpower alarm permission bits Bit5: underpower alarm permission bits
01D1H	465	overvoltage alarm threshold	2	R/W	Int unit 0.1V
01D2H	466	overvoltage alarm time-delay	2	R/W	Int unit 0.01S
01D3H	467	undervoltage alarm threshold	2	R/W	Int unit 0.1V
01D4H	468	undervoltage alarm 468 time-delay		R/W	Int unit 0.01S
01D5H	469	overcurrent alarm threshold	2	R/W	Int unit 0.01A
01D6H	470	Overcurrent alarm time-delay	2	R/W	Int unit 0.01S
01D7H	471	undercurrent alarm threshold	2	R/W	Int unit 0.01A

	_				
01D8H	472	undercurrent alarm time-delay	2	R/W	Int unit 0.01S
01D9H	473	overpower alarm threshold	2	R/W	Int unit 0.001kw
01DAH	474	overpower alarm time-delay	2	R/W	Int unit 0.01S
01DBH	475	underpower alarm threshold	2	R/W	Int
01DCH	476	underpower alarm	2	R/W	unit 0.001kw Int
		time-delay			unit 0.01S 0:Normal Open
01DDH	477	DI1 Original state	2	R/W	1:Normal Close 0:Not associated to DO
01DEH	478	DI1 Setting	2	R/W	1:Associated to DO  2:Associated to DO2
01DFH	479	DI2 Original state	2	R/W	0:Normal Open 1:Normal Close
01E0H	480	DI2 Setting	2	R/W	0:Not associated to DO 1:Associated to DO1 2:Associated to DO2
01E1H	481	DI3 Original state	2	R/W	0:Normal Open 1:Normal Close
01E2H	482	DI3 Setting	2	R/W	0:Not associated to DO 1:Associated to DO1 2:Associated to DO2
01E3H	483	DI4 Original state	2	R/W	0:Normal Open 1:Normal Close
01E4H	484	DI4 Setting	2	R/W	0:Not associated to DO 1:Associated to DO1 2:Associated to DO2
01E5H	485	DO1 Output mode	2	R/W	0:Electrical level 1:Purse
01Е6Н	486	DO1 Related content	2	R/W	0:DO 1: Total failure 2: Total failure +DI1+DI2 3:DI1 4:DI2 5:DI1+DI2
01E7H	487	DO1 Output pulse width	2	R/W	0:None 1:1S 2:2S 3:3S 4:4S 5:5S

01E8H	488	DO2 Output mode	2	R/W	0: Electrical level
O'LOTT	100	DOZ Output mode	2 - surpur meut		1:Purse
					0:DO
					1:Total failure
01E9H	489	DO2 Related content	2	R/W	2: Total failure +DI1+DI2
UILHI	409	DO2 Related content	2	IN W	3:DI1
					4:DI2
					5:DI1+DI2
					0:None
					1:1S
01EAH	490	DO2 Output pulse	2	D/W/	2:2S
VILAN	490	width	2	IN W	3:3S
					4:4S
					5:5S
					Bit0: overvoltages alarm
					Bit1: undervoltage alarm
				Bit2: overcurrent alarm	
					3:3S 4:4S 5:5S  Bit0: overvoltages alarm Bit1: undervoltage alarm Bit2: overcurrent alarm Bit3: undercurrent alarm Bit4: overpower alarm Bit5: underpower alarm Bit6:DO1 alarm Bit7:DO2 alarm Bit8:A phase lost current alarm
			Bit4: overpower ala	Bit4: overpower alarm	
				8 S:DI1+DI2  0:None  1:1S  2:2S  3:3S  4:4S  5:5S  Bit0: overvoltages alarm  Bit1: undervoltage alarm  Bit2: overcurrent alarm  Bit3: undercurrent alarm  Bit4: overpower alarm  Bit5: underpower alarm  Bit6:DO1 alarm  Bit7:DO2 alarm  Bit9:B phase lost current alarm  Bit9:B phase lost current alarm  Bit10:C phase lost current  alarm  Bit11:A phase lost voltage  alarm  Bit12:B phase lost voltage	
					Bit7:DO2 alarm
				Bi	Bit8:A phase lost current alarm
0.1EDII	401		2	, n	Bit9:B phase lost current alarm
01EBH	491	491 Alarm state 2	R	Bit10:C phase lost current	
					alarm
					Bit11:A phase lost voltage
					alarm
					Bit12:B phase lost voltage
					alarm
					Bit13:C phase lost voltage
					alarm
					Bit14: phase sequence error
					alarm
					aialiii

## 6.4 Historical Data Memory

Start address (high byte)	Data type
48-53H	Last 1 month-last 12 months

Start address	Data type
(low byte)	
00H	Record date and time
03H	History total active energy
05H	History total forward active energy
07H	History total reversing active energy
09H	History total forward reactive energy

0.5	
0BH	History total reversing reactive energy
0DH	Total active energy on A phase
0FH	Total forward active energy on A phase
11H	Total reversing active energy on A phase
13H	Total forward reactive energy on A phase
15H	Total reversing reactive energy on A phase
17H	Total active energy on B phase
19H	Total forward active energy on B phase
1BH	Total reversing active energy on B phase
1DH	Total forward reactive energy on B phase
1FH	Total reversing reactive energy on B phase
21H	Total active energy on C phase
23Н	Total forward active energy on C phase
25H	Total reversing active energy on C phase
27H	Total forward reactive energy on C phase
29H	Total reversing reactive energy on C phase
2BH	Current spike electric energy
2DH	Current peak electric energy
2FH	Current flat electric energy
31H	Current valley electric energy
33Н	Current forward active spike electric energy
35H	Current forward active peak electric energy
37H	Current forward active flat electric energy
39Н	Current forward active valley electric energy
3ВН	Current reversing active spike electric energy
3DH	Current reversing Active peak electric energy
3FH	Current reversing active flat electric energy
41H	Current reversing Active valley electric energy
43H	Current forward reactive spike electric energy
45H	Current forward reactive spike electric energy
47H	Current forward reactive flat electric energy
49H	Current forward reactive valley electric energy
4BH	Current reversing reactive spike electric energy
4DH	Current reversing reactive peak electric energy
4FH	Current reversing reactive flat electric energy
51H	Current reversing reactive valley electric energy

## 6.5 Record of extreme value and occurrence time

## 1) Maximum records:

Starting address of interval (high byte)	Type of historical data
04	Extremum of the month and Occurrence time
05	Extremum of last 1 month and Occurrence time
06	Extremum of last 2 month and Occurrence time
07	Extremum of last 3 month and Occurrence time

Offset address of interval (low byte))	Data type
00	Voltage of A phase maximum value
00	and occurrence time
03	Voltage of B phase maximum value
03	and occurrence time
06	Voltage of C phase maximum value
00	and occurrence time
09	Voltage between A-B maximum value
09	and occurrence time
0C	Voltage between A-B maximum value
00	and occurrence time
0F	Voltage between A-B maximum value
OF	and occurrence time
12	Electricity of A phase maximum value
12	and occurrence time
15	Electricity of B phase maximum value
13	and occurrence time
18	Electricity of C phase maximum value
10	and occurrence time
1B	Three phase current vector sum
115	maximum value and occurrence time
1E	Active power of A phase maximum
IL.	value and occurrence time
22	Active power of B phase maximum
22	value and occurrence time
26	Active power of C phase maximum
20	value and occurrence time
2A	Total active power maximum value
271	and occurrence time
2E	Reactive power of A phase maximum
ZL	value and occurrence time
32	Reactive power of B phase maximum
32	value and occurrence time
36	Reactive power of C phase maximum
30	value and occurrence time
3A	Total reactive power maximum value

	and occurrence time
3E	Apparent power of A phase maximum value and occurrence time
42	Apparent power of B phase maximum value and occurrence time
46	Apparent power of C phase maximum value and occurrence time
4A	Total apparent power maximum value and occurrence time

## 2) **Minimum record:**

Starting address of interval (high byte)	Type of historical data
04	Extremum of the month and Occurrence time
05	Extremum of last 1 month and Occurrence time
06	Extremum of last 2 month and Occurrence time
07	Extremum of last 3 month and Occurrence time

Offset address of		
interval (low byte))	Data type	
interval (low byte)		
4E	Voltage of A phase Minimum Value	
	and occurrence time	
51	Voltage of B phase Minimum Value	
	and occurrence time	
54	Voltage of C phase Minimum Value	
	and occurrence time	
57	Voltage between A-B Minimum Value	
57	and occurrence time	
5A	Voltage between B-C Minimum value	
JA	and occurrence time	
5D	Voltage between C-A Minimum value	
	and occurrence time	
60	Electricity of A phase Minimum value	
	and occurrence time	
63	Electricity of B phase Minimum value	
	and occurrence time	
66	Electricity of C phase Minimum value	
	and occurrence time	
69	Three phase current vector sum	
	Minimum value and occurrence time	
6C	Active power of A phase Minimum	
	value and occurrence time	
70	Active power of B phase Minimum	
,0	value and occurrence time	
74	Active power of C phase Minimum	
	value and occurrence time	

78	Total active power Minimum value and occurrence time
7C	Reactive power of A phase Minimum value and occurrence time
80	Reactive power of B phase Minimum value and occurrence time
84	Reactive power of C phase Minimum value and occurrence time
88	Total reactive power Minimum value and occurrence time
8C	Apparent power of A phase Minimum value and occurrence time
90	Apparent power of B phase Minimum value and occurrence time
94	Apparent power of C phase Minimum value and occurrence time
98	Total apparent power Minimum value and occurrence time

Note: The record of every extreme value and occurrence time is 6 bits, and the data configuration can be referred as below:

ADDRH ADDRL	Event names	Data type	Note
0400H	Maximum voltage of	The data of Maximum voltage of A phase	data and decimal place refer to address table 6.2
0401H	A phase and occurrence time	Occurrence time of minutes and hours	high byte : minutes
0402H		Occurrence time of Days and months	high byte : Days

## 7 Common troubleshooting

### 7.1 RS485 networking communication failure

Suggestion: Please first confirm whether the RS485 wiring is loose, AB connection reverse and other problems, and then check the table through the button to see if the general selection parameters, such as address, baud rate, check digit, etc., are set correctly.

#### 7.2 Wireless communication failure of instrumentation

Suggestion: Please connect RS485 interface on the meter and USB convert to 485 serial port to read the parameters, and confirm whether the parameters are the same as the upper terminal wireless configuration (channel and spread spectrum factor). If different, please modify the meter's wireless parameters and retest the master terminal after the same, and if the same, it may be the meter and master terminal are in a relative long distance. It is too far to communicate or the scene is seriously disturbed. We can try to use the external antenna at the same time, or consider the newly added wireless master terminals, and then test it.